





**Certificate:** 2022442  
**Project:** 70107190

**Master Contract:** 189705  
**Date Issued:** 2017-11-13

---

### **Part C**

Accessories Bridging bars Catalogue number 41593063, 41594063 are intended to be used on open type double throw manual switches SIRCOVER 600.

Accessories Bridging bars Catalogue number 41593080, 41594080 are intended to be used on open type double throw manual switches SIRCOVER 800 or SIRCOVER 1200.

Accessories Terminal screens Catalogue number 16093063, 16094063 are intended to be used on open type double throw manual switches SIRCOVER 600.

Accessories Terminal screens Cat. Nos. 16093080, 16094080 are intended to be used on open type double throw manual switches SIRCOVER 800 or SIRCOVER 1200.

Accessories Handle Catalogue number 41997012 is intended to be used on open type double throw manual switches SIRCOVER 600, 800 and 1200.

Accessories Handle Catalogue number 41997062 is a direct handle. Accessories Handle Catalogue number 41997149 is an external handle. These handles are intended to be used on open type double throw manual switches SIRCOVER 600, 800 and 1200.

Accessories shaft type V Cat. Nos. 41993018, 41993019. These shafts are intended to be used on open type double throw manual switches SIRCOVER 600, 800 and 1200.

#### **Note:**

- 1) For use in enclosure minimum size 48 inches by 36 inches by 20 inches for SIRCOVER 600
- 2) For use in enclosure minimum size 60 inches by 36 inches by 20 inches for SIRCOVER 800A and 1200A.
- 3) These devices are certified as components for use in equipment where the suitability of the combination is determined by CSA International.

### **APPLICABLE REQUIREMENTS**

CSA C22.2 No.4-16 - Enclosed and Dead-Front Switches



## *Supplement to Certificate of Compliance*

**Certificate:** 2022442

**Master Contract:** 189705 (112964)

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
70107190	2017-11-13	Update report as per Notice 17 and 21 (CSA C22.2 No.4-16).
2676042	2014-01-21	Modification of short-circuit rating of 250Vdc at 100kA.
2479891	2011-12-22	Addition of SIRCOVER 600 rating 600A/600Vac, 600A/250Vdc and 20kA/250Vac.
2022442	2008-07-10	New certification: open type double throw manual switches with off position: SIRCOVER 600, 800, 1200.