

IEC**IECEE**

® TM

Ref. Certif. No.

CN59621

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Transfer Switching Equipment

Name and address of the applicant

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

Note: When more than one factory, please report on page 2

SOCOMECELECTRIC (SHANGHAI) CO.,LTD
Building A30, No.5399 Waiqingsong Road Qing Pu.Shanghai
P.R.ChinaAdditional information on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

ATyS 250A,ATyS d 250A, ATyS t 250A, ATyS g 250A,ATyS p 250A, ATyS A
250A,ATyS C 250A, ATyS 315A,ATyS d 315A,ATyS t 315A, ATyS g
315A,ATyS p 315A,ATyS A 315A,ATyS C 315A, ATyS 400A,ATyS d
400A,ATyS t 400A,ATyS g 400A,ATyS p 400A,ATyS A 400A,ATyS C 400A

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-6-1:2005 (2nd Edition) + AMD 1:2013 for use in conjunction with IEC 60947-1:2007 (5th Edition) + AMD 1:2010

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2022CQC-103451

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRESection 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Jun.06,2023

Signature:

谢肇旭

Xie ZhaoXu

CB 0073737

ATyS 250A,ATyS d 250A, ATyS t 250A, ATyS g 250A,ATyS p 250A, ATyS A 250A,ATyS C 250A,
ATyS 315A,ATyS d 315A,ATyS t 315A, ATyS g 315A,ATyS p 315A,ATyS A 315A,ATyS C 315A,
ATyS 400A,ATyS d 400A,ATyS t 400A,ATyS g 400A,ATyS p 400A,ATyS A 400A,ATyS C 400A

Ui: 1000V(Main circuit), 300V(Control circuit);

Uimp: 10kV(Main circuit), 4kV(Control circuit);

Ue: AC415V;

ATyS 250A,ATyS d 250A,ATyS t 250A,ATyS g 250A,ATyS p 250A,ATyS A 250A,ATyS C 250A:

Ith: 250A;

Ie: 125A,160A,200A(AC-33B); 250A(AC-32B);

ATyS 315A,ATyS d 315A,ATyS t 315A, ATyS g 315A,ATyS p 315A,ATyS A 315A,ATyS C 315A:

Ith: 315A;

Ie: 315A(AC-32B); 200A(AC-33B);

ATyS 400A,ATyS d 400A,ATyS t 400A,ATyS g 400A,ATyS p 400A,ATyS A 400A,ATyS C 400A:

Ith: 400A;

Ie: 400A(AC-32B); 200A(AC-33B)

Utilization Category: AC-32B, AC-33B;

Icm(Peak):17kA;Icw: 10kA(30ms);

Iq: 50kA;

ATSE,RTSE;

PC;

3P, 4P

Additional information (if necessary)

Date: Jun.06,2023

Signature:

谢肇煦

Xie ZhaoXu

IEC**IECEE**

®

TM

Ref. Certif. No.


CN59621

Name of the factory	Address of the factory
SOCIETE TIMELEC SARL	ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS, Tunisia
SOCOMECS.A.S	1, Rue De Westhouse 67230 Benfeld Cedex France

Additional information (if necessary)

Date: Jun.06,2023

Signature:



Xie ZhaoXu