

DIRIS A-30/A-41

RS485 – PROFIBUS® DP

EN Operating instructions



PRELIMINARY OPERATIONS	4
GENERAL INFORMATION	4
INSTALLATION.....	5
PROGRAMMING	6
CONFIGURATION	10
USE OF PROFIBUS®-DP MODULES.....	15
MODULE 1 : MAIN MEASUREMENTS	15
MODULE 2 : ADDITIONAL MEASUREMENTS	20
MODULE 3 : TROUGH/POWER CUT/ MEAN POWER.....	22
MODULE 4 : OVERVOLTAGE/MEAN VOLTAGE AND FREQUENCIES/MAXIMUM IN AND MEAN IN.....	23
MODULE 5 : CURRENT HARMONICS	24
MODULE 6 : PHASE TO PHASE VOLTAGE	25
MODULE 7 : PHASE TO NEUTRAL VOLTAGE.....	26
MODULE 8 : INSTANTANEOUS MIN/MAX.....	27
MODULE 9 : SPECIAL FRAME	28
MODULE 11 : LIMITED SPECIAL FRAME	36
DIAGNOSTICS	37
TECHNICAL CHARACTERISTICS.....	39

PRELIMINARY OPERATIONS

For personnel and product safety please read the contents of these operating instructions carefully before connecting.

Check the following points as soon as you receive the **Diris A-30/A-41** package:

- the packing is in good condition,
- the product has not been damaged during transit,

- the product reference number conforms to your order,
- the package contains the product,
- a CD-Rom.


GENERAL INFORMATION

Functions

This optional module must be connected to the **DIRIS A-30/A-41** (ref. 4825 0201, 4825 1201, 4825 U201, 4825 0211, 4825 0202, 4825 1202). It provides an RS485 serial link (2 or 3 wires) with PROFIBUS® DP protocol for the use of **DIRIS A-30/A-41** from a PC or PLC.

General points

In a standard configuration, an RS485 link allows 1 to 32 **DIRIS A-30/A-41** to be linked to 1 to 32 pieces of equipment using the PROFIBUS®-DP protocol. The maximum communication speed is 1.5 Mbauds over 200 m. This distance can be increased if the speed is reduced (Standards: EN50170).



Recommendations:

You should use a guaranteed cable PROFIBUS.

NB :

An active termination must be fitted at both ends of the connection, which can be found either on the RS485 module (attached by moving the 2 switches to ON), or directly on the PROFIBUS-DP connector (D-Sub 9-pin).

INSTALLATION


CONNECTION

The option modules are installed on the rear panel of the **DIRIS A-30/A-41** in one of the four positions provided.



The **DIRIS A-30/A-41** must be switched off


1



DIRIS 342 A


2

Fix the option modules next to each other



DIRIS 343 A


3



DIRIS 469 B

4

Follow indications when connecting the terminal Switch on voltage supply



DIRIS 469 B


Note :

Correspondence with a HAN BRID connector

+ = B (red)


- = A (green)

PROGRAMMATION



COMMUNICATION ADDRESS


> Example : COM ADR = 7



PROGRAMMATION

DIAGNOSTIQUE

> Example : COM DIAG = NO




NB :

This function allows switching the diagnosis function or off. (see p. 37)

ACTIVATION OF THE PROGRAMME VIA THE PROFIBUS MASTER

> Example : COM PARA = YES



Nb :

This function allows activating or deactivation of the DIRIS programming by the PROFIBUS DP master. If this function is deactivated please note that in case of loss of the slave (**DIRIS**) the master will not send the GSD file parameters and thus won't re-programme the **DIRIS A** with the factory parameters.

CONFIGURATION

The table below gives the configuration of the **DIRIS A-30/A-41** used when starting a PROFIBUS®-DP cycle.

Name	Size (bytes)
Manufacturer parameter ⚠ Always equal to zero	1
Network type 0 : 1 BL 1 : 2 BL 2 : 3 BL 3 : 3 NBL 4 : 4 BL 5 : 4 NBL	1
CT secondary (A) 1 : 1 A 5 : 5 A	1
CT primary (A)	2
Voltage input on PT 0 : No 1 : Yes	1
PT primary (V)	4
PT secondary (V) 60 : 60 V 100 : 100 V 110 : 110 V 115 : 115 V 120 : 120 V 173 : 173 V 190 : 190 V	1
Synchronisation of I AVG / MAX 5 : 5 mn 8 : 8 mn 10 : 10 mn 15 : 15 mn 20 : 20 mn 30 : 30 mn 60 : 60 mn	1
Synchronisation of P / Q / S AVG / MAX 5 : 5 mn 8 : 8 mn 10 : 10 mn 15 : 15 mn 20 : 20 mn 30 : 30 mn 60 : 60 mn	1
OUT 1 allocation 0 : kWh+ 1 : kvarh+ 2 : kVAh 3 : kWh- 4 : kvarh-	1
OUT 1 impulse value (kWh / kvarh / kVAh) 0 : 0,1 1 : 1 2 : 10	1

Name	Size (bytes)
3 : 100 4 : 1000 5 : 10000	
OUT 1 impulse duration (ms) 1 : 100 2 : 200 3 : 300 4 : 400 5 : 500 6 : 600 7 : 700 8 : 800 9 : 900	1
OUT 2 allocation 0 : kWh+ 1 : kvarh+ 2 : kVAh 3 : kWh- 4 : kvarh-	1
OUT 2 impulse value (kWh / kvarh / kVAh) 0 : 0,1 1 : 1 2 : 10 3 : 100 4 : 1000 5 : 10000	1
OUT 2 impulse duration (ms) 1 : 100 2 : 200 3 : 300 4 : 400 5 : 500 6 : 600 7 : 700 8 : 800 9 : 900	1
Analog output type OUT 1 0 : 0 / 20 mA 1 : 4 / 20 mA 2 : Alim	1
Allocation of analog output OUT 1 0 : I1 1 : I2 2 : I3 3 : In 4 : U12 5 : U23 6 : U31 7 : P 8 : Q 9 : S	1

CONFIGURATION

Name	Size (bytes)
10 : PF 11 : V1 12 : V2 13 : V3 14 : F	
Value at 0 or 4 mA from analog output OUT 1	2
Unit at 0 or 4 mA from analog output OUT 1 0 : / 1 : k 2 : M	1
Value at 20 mA from analog output OUT 1	2
Unit at 20 mA from analog output OUT 1 0 : / 1 : k 2 : M	1
Analog output type OUT 2 0 : 0 / 20 mA 1 : 4 / 20 mA 2 : Alim	1
Allocation of analog output OUT 2 0 : I1 1 : I2 2 : I3 3 : In 4 : U12 5 : U23 6 : U31 7 : P 8 : Q 9 : S 10 : PF 11 : V1 12 : V2 13 : V3 14 : F	1
Value at 0 or 4 mA from analog output OUT 2	2
Unit at 0 or 4 mA from analog output OUT 2 0 : / 1 : k 2 : M	1
Value at 20 mA from analog output OUT 2	2
Unit at 20 mA from analog output OUT 2 0 : / 1 : k 2 : M	1
Analog output type OUT 3 0 : 0 / 20 mA 1 : 4 / 20 mA 2 : Supply	1

Name	Size (bytes)
Allocation of analog output OUT 3 0 : I1 1 : I2 2 : I3 3 : In 4 : U12 5 : U23 6 : U31 7 : P 8 : Q 9 : S 10 : PF 11 : V1 12 : V2 13 : V3 14 : F	1
Value at 0 or 4 mA from analog output OUT 3	2
Unit at 0 or 4 mA from analog output OUT 3 0 : / 1 : k 2 : M	1
Value at 20 mA from analog output OUT 3	2
Unit at 20 mA from analog output OUT 3 0 : / 1 : k 2 : M	1
Analog output type OUT 4 0 : 0 / 20 mA 1 : 4 / 20 mA 2 : Supply	1
Allocation of analog output OUT 4 0 : I1 1 : I2 2 : I3 3 : In 4 : U12 5 : U23 6 : U31 7 : P 8 : Q 9 : S 10 : PF 11 : V1 12 : V2 13 : V3 14 : F	1
Value at 0 or 4 mA from analog output OUT 4	2
Unit at 0 or 4 mA from analog output OUT 4 0 : / 1 : k 2 : M	1

CONFIGURATION

Name	Size (bytes)
Value at 20 mA from analog output OUT 4	2
Unit at 20 mA from analog output OUT 4 0 : / 1 : k 2 : M	1
CT In secondary (A) 1 : 1 A 5 : 5 A	1
CT In primary (A)	2

Length: 54 bytes

NB:

All this information is integrated in the GSD file
(User-Prm-Data).



Check that the parameterisation data are identical to the data programmed in the device.

When the PROFIBUS® master loses a slave, it re-injects the parameters from the GSD file which will re set the factory configuration.

There are two solutions to inhibit this function:

- Deactivate the master's DIRIS A programming (see also page 9)
- Configure the *DIRIS A* through the master, then open and close the *DIRIS A* programming menu directly by the keypad (code =100).

USE OF THE PROFIBUS®-DP MODULES

The modules contain the inputs (display) and outputs (configuration).

MODULE 1: MAIN MEASUREMENTS

This module contains the currents, powers, frequencies, power factor, positive energies and hour meter.

Example:

Modification of relay 1:

- set bit 4 (relay configuration change),
- set bit 0 (relay 1 to 1),
- modify the status byte on relay 1 break (next byte).

Output frame

Name	Size (bytes)
Change of relay status if bit on 1, then taken into account, otherwise bit on 0 bit 0: Relay 1 bit 1: Relay 2 bit 2: Relay 3 (second option relay 1) bit 3: Relay 4 (second option relay 2) bit 4: Change in relay configuration bit 5: Resetting of one measurement bit 6: not used bit 7: not used	1
Relay 1 on break 0: open 1: closed	1
Relay 2 on break 0: open 1: closed	1
Relay 3 on break 0: open 1: closed	1
Relay 4 on break 0: open 1: closed	1
Allocation OUT 1 0: Cde 1: I 2: U 3: P+ 4: Q+ 5: S 6: F 7: PFL 8: Thd 3I 9: Thd 3U 10: In 11: time 12: V 13: Thd In 14: Thd 3V 15: P- 16: Q- 17: PFC	1
Lower threshold OUT 1	2
Lower threshold unit OUT 1 0: / 1: k 2: M	1
Upper threshold OUT 1	2

USE OF THE PROFIBUS®-DP MODULES

MODULE 1: MAIN MEASUREMENTS

Output frame

Name	Size (bytes)
Upper threshold unit OUT 1 0: / 1: k 2: M	1
Hysteresis 0 to 99 OUT 1 (%)	1
Time delay OUT 1 (s)	2
Allocation OUT 2 0: Cde 1: I 2: U 3: P+ 4: Q+ 5: S 6: F 7: PFL 8: Thd 3I 9: Thd 3U 10: In 11: time 12: V 13: Thd In 14: Thd 3V 15: P- 16: Q- 17: PFC	1
Lower threshold OUT 2	2
Lower threshold unit OUT 2 0: / 1: k 2: M	1
Upper threshold OUT 2	2
Upper threshold unit OUT 2 0: / 1: k 2: M	1
Hysteresis 0 to 99 OUT 2 (%)	1
Time delay OUT 2 (s)	2
Zero reset bit 0: Max 3I bit 1: Max P+ bit 2: Max P- bit 3: Max Q+ bit 4: Max Q- bit 5: Max S bit 6: hour meter bit 7: kWh+ bit 8: kvarh+ bit 9: kVA bit 10: kWh- bit 11: kvarh- bit 12: all the parameters bit 13: Input 1 bit 14: Input2 bit 15: not used	2

MODULE 1: MAIN MEASUREMENTS

Output frame

Name	Size (bytes)
Zero reset, supplementary options bit 0: Input 1 bit 1: Input 2 bit 2: Input 3 bit 3: Input 4 bit 4: Not used bit 5: Not used bit 6: Min Max I bit 7: Min Max In bit 8: Min Max U bit 9: Min Max Frequency bit 10: Min Max PF bit 11: Min Max P bit 12: Min Max Q bit 13: Min Max Thd I bit 14: Min Max Thd In bit 15: Min Max Thd U	2

Length: 29 bytes

USE OF THE PROFIBUS®-DP MODULES

MODULE 1: MAIN MEASUREMENTS

Frame of inputs not allocated for current and voltage transformation ratios

Name	Size (bytes)
Phase 1 current (mA)	2
Phase 2 current (mA)	2
Phase 3 current (mA)	2
Neutral current (mA)	2
Phase to phase voltage U12 (V / 10)	2
Phase to phase voltage U23 (V / 10)	2
Phase to phase voltage U31 (V / 10)	2
Phase to neutral voltage phase 1 (V / 10)	2
Phase to neutral voltage phase 2 (V / 10)	2
Phase to neutral voltage phase 3 (V / 10)	2
Frequency (Hz / 100)	2
Σ Active power +/- (kW / 10)	2
Σ Reactive power +/- (kvar / 10)	2
Σ Apparent power +/- (kVa / 10)	2
Σ Power factor L / C -: capacitive and +: inductive (0.001)	2
I1 max (mA)	2
I2 max (mA)	2
I3 max (mA)	2
Maximum value active power + (W)	2
Maximum value active power - (W)	2
Maximum value reactive power + (var)	2
Maximum value reactive power - (var)	2
Maximum apparent power (VA)	2
Active energy + < 10000 (kWh)	2
Active energy + > 10000 (kWh)	2
Reactive energy + < 10000 (kvarh)	2
Reactive energy + > 10000 (kvarh)	2
Apparent energy < 10000 (kVAh)	2
Apparent energy > 10000 (kVAh)	2
System I (mA)	2
System U (V / 10)	2
System V (V / 10)	2
Hour meter < 10000 (H / 100)	2
Hour meter >10000 (H / 100)	2

Length: 68 bytes

Calculation of the values allocated:

The currents must be multiplied by the CT ratio, the voltages by the PT ratio (in HV) and the powers by the ratio CT x PT.

Example:

$$CT = \frac{100}{5} = 20 \quad VT = \frac{20000}{100} = 200$$

$$CT \times VT = 20 \times 200 \\ = 4000$$

Powers will be multiplied by 4000 (if there is no VT, then VT = 1), currents by 20 and voltages by 200.

NB :

$$I_{\text{system}} = \frac{I_1 + I_2 + I_3}{3}$$

$$U_{\text{system}} = \frac{U_{12} + U_{21} + U_{31}}{3}$$

$$V_{\text{system}} = \frac{V_1 + V_2 + V_3}{3}$$

Transformation of signed values into unsigned values

If the currents, voltages or energies are negative, the following rule must be applied:

- take the opposite bit by bit of the datum
- add 1 to this opposite

Example:

- negative datum - 28864mv
or in binary : 0111 0000 1100 0000
- opposite is equal to : 1000 1111 0011 1111
- opposite + 1 is equal to : 1000 1111 0100 0000
or in decimal 366,72.

USE OF THE PROFIBUS®-DP MODULES

MODULE 2: SUPPLEMENTARY MEASUREMENTS

This module contains the measurements by phase, average values, negative energies, impulse meters (on / off inputs) and statuses (on / off inputs).

The output frame is identical to module 1.

Input frame

Name	Size (bytes)
Active power phase 1 +/- (kW/10)	2
Active power phase 2 +/- (kW/10)	2
Active power phase 3 +/- (kW/10)	2
Reactive power phase 1 +/- (kvar/10)	2
Reactive power phase 2 +/- (kvar/10)	2
Reactive power phase 3 +/- (kvar/10)	2
Apparent power phase 1 (kVA/10)	2
Apparent power phase 2 (kVA/10)	2
Apparent power phase 3 (kVA/10)	2
Power factor phase 1 (0.001) -: capacitive and +: inductive	2
Power factor phase 2 (0.001) -: capacitive and +: inductive	2
Power factor phase 3 (0.001) -: capacitive and +: inductive	2
Average value I1 (mA)	2
Average value I2 (mA)	2
Average value I3 (mA)	2
Average value active power + (W)	2
Average value active power - (W)	2
Average value reactive power + (var)	2
Average value reactive power - (var)	2
Average value apparent power (VA)	2
Active energy - < 10000 (kWh)	2
Active energy - >10000 (kWh)	2
Reactive energy - < 10000 (kvarh)	2
Reactive energy - > 10000 (kvarh)	2
Input pulse meter 1 < 10000	2
Input pulse meter 1 > 10000	2
Input pulse meter 2 < 10000	2
Input pulse meter 2 > 10000	2
Input pulse meter 3 < 10000	2
Input pulse meter 3 > 10000	2
Input pulse meter 4 < 10000	2
Input pulse meter 4 > 10000	2
Status inputs 1, 2, 3, 4.	2

Length: 66 bytes

Calculation of the values allocated:

The currents must be multiplied by the CT ratio, the voltages by the PT ratio (in HV) and the powers by the CT x PT ratio.

Example:

$$CT = \frac{100}{5} = 20 \quad VT = \frac{20000}{100} = 200$$

$$CT \times VT = 20 \times 200 \\ = 4000$$

Powers will be multiplied by 4000 (if there is no VT, then VT = 1), currents by 20 and voltages by 200.

Status of the inputs :

input 1 = bit 0

input 2 = bit 1

input 3 = bit 2

input 4 = bit 4

If active the bit is on 1.

If inactive the bit is on 0.

Transformation of signed values into unsigned values

If the currents, voltages or energies are negative, the following rule must be applied:

- take the opposite bit by bit of the datum
- add 1 to this opposite

Example:

- negative datum - 28864mv
or in binary : 0111 0000 1100 0000
- opposite is equal to : 1000 1111 0011 1111
- opposite + 1 is equal to : 1000 1111 0100 0000
or in decimal 366,72 V.

USE OF THE PROFIBUS®-DP MODULES

MODULE 3: DIPS/INTERRUPTION/TREND POWERS AND FREQUENCY

Name	Size (bytes)
Last voltage dips	
Residual phase to phase voltage involved: 0: none, 5: U12, 6: U23, 7: U31	1
Value (V/100)	4
Residual phase to neutral voltage involved: 0: none, 22 : V1, 23: V2, 24: V3	1
Value (V/100)	4
Length (ms)	4
Month	1
Day	1
Year	1
Hour	1
Minute	1
Second	1
Last power interruption	
Month	1
Day	1
Year	1
Hour	1
Minute	1
Second	1
Last average power	
Last P+ value (kW/10)	2
Last P- value (kW/10)	2
Last Q+ value (kvar/10)	2
Last Q- value (kvar/10)	2
Last average frequency	
Last frequency value (Hz/100)	2

Length: 36 bytes

MODULE 4: SWELL/TREND VOLTAGES/IN MAXIMUM AND AVERAGE

Name	Size (bytes)
Last swell	
Maximum phase to phase voltage involved: 0: none, 5: U12, 6: U23, 7: U31	1
Value (V/100)	4
Maximum phase to neutral voltage involved: 0: none, 22 : V1, 23: V2, 24: V3	1
Value (V/100)	4
Length (ms)	4
Month	1
Day	1
Year	1
Hour	1
Minute	1
Second	1
Average voltage	
Last phase to phase voltage value U12 (V/10)	2
Last phase to phase voltage value U23 (V/10)	2
Last phase to phase voltage value U31 (V/10)	2
Last phase to neutral voltage value V1 (V/10)	2
Last phase to neutral voltage value V2 (V/10)	2
Last phase to neutral voltage value V3 (V/10)	2
Average and maximum neutral current	
Average In (mA)	2
Average maximum In (mA)	2

Length: 36 bytes

USE OF THE PROFIBUS®-DP MODULES

MODULE 5: CURRENT HARMONICS

This module contains the thd Is, the thd INs and the individual harmonics up to number 15.

The output frame is identical to module 1.

Input frame

Name	Size (bytes)
Thd I1 (0.1 %)	2
Thd I2 (0.1 %)	2
Thd I3 (0.1 %)	2
Thd In (0.1 %)	2
Harmonic I1 row 3 (0.1 %)	2
Harmonic I2 row 3 (0.1 %)	2
Harmonic I3 row 3 (0.1 %)	2
Harmonic In row 3 (0.1 %)	2
Harmonic I1 row 5 (0.1 %)	2
Harmonic I2 row 5 (0.1 %)	2
Harmonic I3 row 5 (0.1 %)	2
Harmonic In row 5 (0.1 %)	2
Harmonic I1 row 7 (0.1 %)	2
Harmonic I2 row 7 (0.1 %)	2
Harmonic I3 row 7 (0.1 %)	2
Harmonic In row 7 (0.1 %)	2
Harmonic I1 row 9 (0.1 %)	2
Harmonic I2 row 9 (0.1 %)	2
Harmonic I3 row 9 (0.1 %)	2
Harmonic In row 9 (0.1 %)	2
Harmonic I1 row 11 (0.1 %)	2
Harmonic I2 row 11 (0.1 %)	2
Harmonic I3 row 11 (0.1 %)	2
Harmonic In row 11 (0.1 %)	2
Harmonic I1 row 13 (0.1 %)	2
Harmonic I2 row 13 (0.1 %)	2
Harmonic I3 row 13 (0.1 %)	2
Harmonic In row 13 (0.1 %)	2
Harmonic I1 row 15 (0.1 %)	2
Harmonic I2 row 15 (0.1 %)	2
Harmonic I3 row 15 (0.1 %)	2
Harmonic In row 15 (0.1 %)	2

Length: 64 bytes

NB:

The individual harmonics are available if the harmonic module is connected.

MODULE 6: PHASE TO PHASE VOLTAGE HARMONICS

This module contains the thd 3U and the individual harmonics up to number 15.

The output frame is identical to module 1.

Input frame

Name	Size (bytes)
Thd U12 (0.1 %)	2
Thd U23 (0.1 %)	2
Thd U31 (0.1 %)	2
Harmonic U12 row 3 (0.1 %)	2
Harmonic U23 row 3 (0.1 %)	2
Harmonic U31 row 3 (0.1 %)	2
Harmonic U12 row 5 (0.1 %)	2
Harmonic U23 row 5 (0.1 %)	2
Harmonic U31 row 5 (0.1 %)	2
Harmonic U12 row 7 (0.1 %)	2
Harmonic U23 row 7 (0.1 %)	2
Harmonic U31 row 7 (0.1 %)	2
Harmonic U12 row 9 (0.1 %)	2
Harmonic U23 row 9 (0.1 %)	2
Harmonic U31 row 9 (0.1 %)	2
Harmonic U12 row 11 (0.1 %)	2
Harmonic U23 row 11 (0.1 %)	2
Harmonic U31 row 11 (0.1 %)	2
Harmonic U12 row 13 (0.1 %)	2
Harmonic U23 row 13 (0.1 %)	2
Harmonic U31 row 13 (0.1 %)	2
Harmonic U12 row 15 (0.1 %)	2
Harmonic U23 row 15 (0.1 %)	2
Harmonic U31 row 15 (0.1 %)	2

Length: 48 bytes

NB:

The individual harmonics are available if the harmonic module is connected.

USE OF THE PROFIBUS®-DP MODULES

MODULE 7: PHASE TO NEUTRAL VOLTAGE HARMONICS

This module contains the thd 3V and the individual harmonics up to number 15.

The output frame is identical to module 1.

Input frame

Name	Size (bytes)
Thd V1 (0.1 %)	2
Thd V2 (0.1 %)	2
Thd V3 (0.1 %)	2
Harmonic V1 row 3 (0.1 %)	2
Harmonic V2 row 3 (0.1 %)	2
Harmonic V3 row 3 (0.1 %)	2
Harmonic V1 row 5 (0.1 %)	2
Harmonic V2 row 5 (0.1 %)	2
Harmonic V3 row 5 (0.1 %)	2
Harmonic V1 row 7 (0.1 %)	2
Harmonic V2 row 7 (0.1 %)	2
Harmonic V3 row 7 (0.1 %)	2
Harmonic V1 row 9 (0.1 %)	2
Harmonic V2 row 9 (0.1 %)	2
Harmonic V3 row 9 (0.1 %)	2
Harmonic V1 row 11 (0.1 %)	2
Harmonic V2 row 11 (0.1 %)	2
Harmonic V3 row 11 (0.1 %)	2
Harmonic V1 row 13 (0.1 %)	2
Harmonic V2 row 13 (0.1 %)	2
Harmonic V3 row 13 (0.1 %)	2
Harmonic V1 row 15 (0.1 %)	2
Harmonic V2 row 15 (0.1 %)	2
Harmonic V3 row 15 (0.1 %)	2

Length: 48 bytes

NB:

The individual harmonics are available if the harmonic module is connected.

MODULE 8: MIN / MAX INSTANTS

This module contains the storage of the minimum and maximum values (if the 2 input / 2 output module is installed).

The output frame is identical to module 1.

Input frame

Name	Size (bytes)
Min. current (mA)	2
Min. neutral current (mA)	2
Min. phase to phase voltage (V/10)	2
Min. frequency (Hz/100)	2
Min. power factor (0.001)	2
Min. active power (W)	2
Min. reactive power (var)	2
Thd I min (0.1 %)	2
Thd In min (0.1 %)	2
Thd U min (0.1 %)	2
Max. current (mA)	2
Max. neutral current (mA)	2
Max. phase to phase voltage (V/10)	2
Max. frequency (Hz/100)	2
Max. power factor (0.001)	2
Max. active power (W)	2
Max. reactive power (var)	2
Thd I max (0.1 %)	2
Thd In max (0.1 %)	2
Thd U max (0.1 %)	2

Length: 48 bytes

This module allows the creation of a personalised module.

If bit 7 is on 0, then the output frame is a normal frame

28 EN

MODULE 9: SPECIAL FRAME

Input frame

Name	Size (bytes)
Upper threshold unit OUT 1 0: / 1: k 2: M	1
Hysteresis 0 to 99 OUT 1 (%)	1
Time delay OUT 1 (s)	2
Allocation OUT 2: – 0: Cde 1: I 2: U 3: P+ 4: Q+ 5: S 6: F 7: PFL 8: Thd 3I 9: Thd 3U 10: In 11: time 12: V 13: Thd In 14: Thd 3V 15: P- 16: Q- 17: PFC	1
Lower threshold OUT 2	2
Lower threshold unit OUT 2 0: / 1: k 2: M	1
Upper threshold OUT 2	2
Upper threshold unit OUT 2 0: / 1: k 2: M	1
Hysteresis 0 to 99 OUT 2 (%)	1
Time delay OUT 2 (s)	2
Zero reset bit 0: Max 3I bit 1: Max P+ bit 2: Max P- bit 3: Max Q+ bit 4: Max Q- bit 5: Max S bit 6: hour meter bit 7: kWh+ bit 8: kvarh+ bit 9: kVA bit 10: kWh- bit 11: kvarh- bit 12: all the parameters bit 13: Input 1	2

USE OF THE PROFIBUS®-DP MODULES

MODULE 9: SPECIAL FRAME

Input frame

Name	Size (bytes)
bit 14: Input2 bit 15: not used	
Zero reset, supplementary options bit 0: Input 1 bit 1: Input 2 bit 2: Input 3 bit 3: Input 4 bit 4: Input 5 bit 5: Input 6 bit 6: Min Max I bit 7: Min Max In bit 8: Min Max U bit 9: Min Max Frequency bit 10: Min Max PF bit 11: Min Max P bit 12: Min Max Q bit 13: Min Max Thd I bit 14: Min Max Thd In bit 15: Min Max Thd U	2
Not used	4

Length: 33 bytes

If the bit is on 1, then the output frame is as follows

Name	Size (bytes)
Frame number bit 0-6: frame number bit 7: 1 -> address frame	1
Address of value 1	2
Address of value 2	2
Address of value 3	2
Address of value 4	2
Address of value 5	2
Address of value 6	2
Address of value 7	2
Address of value 8	2
Address of value 9	2
Address of value 10	2
Address of value 11	2
Address of value 12	2
Address of value 13	2
Address of value 14	2
Address of value 15	2
Address of value 16	2

NB:

The frame number is an identification number. It is used to check if the answer coming from the slave device corresponds to the PLC's request.

The list of values is available p. 31 to 35.

MODULE 9: SPECIAL FRAME

List of values

Name	Decimal address	Hexa. address
Phase 1 current (mA)	0	0000
Phase 2 current (mA)	1	0001
Phase 3 current (mA)	2	0002
Neutral current (mA)	3	0003
Phase to phase voltage U12 (V/10)	4	0004
Phase to phase voltage U23 (V/10)	5	0005
Phase to phase voltage U31 (V/10)	6	0006
Phase to neutral voltage phase 1 (V/10)	7	0007
Phase to neutral voltage phase 2 (V/10)	8	0008
Phase to neutral voltage phase 3 (V/10)	9	0009
Frequency (Hz/100)	10	000A
_ Active power (W)	11	000B
_ Reactive power (var)	12	000C
_ Apparent power (VA)	13	000D
_ Power factor L / C (0.001)	14	000E
Max. value I1 (mA)	15	000F
Max. value I2 (mA)	16	0010
Max. value I3 (mA)	17	0011
Maximum value active power + (W)	18	0012
Maximum value active power - (W)	19	0013
Maximum value reactive power + (var)	20	0014
Maximum value reactive power - (var)	21	0015
Maximum value apparent power (VA)	22	0016
Active energy + < 10000 (kWh)	23	0017
Active energy + > 10000 (kWh)	24	0018
Reactive energy + < 10000 (kvarh)	25	0019
Reactive energy + > 10000 (kvarh)	26	001A
Apparent energy < 10000 (kVAh)	27	001B
Apparent energy > 10000 (kVAh)	28	001C
Active power phase 1 (W)	29	001D
Active power phase 2 (W)	30	001E
Active power phase 3 (W)	31	001F
Reactive power phase 1 (var)	32	0020
Reactive power phase 2 (var)	33	0021
Reactive power phase 3 (var)	34	0022
Apparent power phase 1 (VA)	35	0023
Apparent power phase 2 (VA)	36	0024
Apparent power phase 3 (VA)	37	0025
Power factor phase 1 (0.001)	38	0026
Power factor phase 2 (0.001)	39	0027
Power factor phase 3 (0.001)	40	0028
Average value I1 (mA)	41	0029
Average value I2 (mA)	42	002A
Average value I3 (mA)	43	002B
Average value active power + (W)	44	002C
Average value active power - (W)	45	002D
Average value reactive power + (var)	46	002E
Average value reactive power - (var)	47	002F
Average value Apparent power (VA)	48	0030
Active energy - < 10000	49	0031
Active energy - >10000	50	0032

USE OF THE PROFIBUS®-DP MODULES

MODULE 9: SPECIAL FRAME

List of values

Name	Decimal address	Hexa. address
Reactive energy - < 10000	51	0033
Reactive energy - > 10000	52	0034
Input pulse meter 1 < 10000	53	0035
Input pulse meter 1 > 10000	54	0036
Input pulse meter 2 < 10000	55	0037
Input pulse meter 2 > 10000	56	0038
Input pulse meter 3 < 10000	57	0039
Input pulse meter 3 > 10000	58	003A
Input pulse meter 4 < 10000	59	003B
Input pulse meter 4 > 10000	60	003C
Status inputs 1 2 3 4	61	003D
Thd I1	62	003E
Thd I2	63	003F
Thd I3	64	0040
Thd In	65	0041
Harmonic I1 row 3	66	0042
Harmonic I2 row 3	67	0043
Harmonic I3 row 3	68	0044
Harmonic IN row 3	69	0045
Harmonic I1 row 5	70	0046
Harmonic I2 row 5	71	0047
Harmonic I3 row 5	72	0048
Harmonic IN row 5	73	0049
Harmonic I1 row 7	74	004A
Harmonic I2 row 7	75	004B
Harmonic I3 row 7	76	004C
Harmonic IN row 7	77	004D
Harmonic I1 row 9	78	004E
Harmonic I2 row 9	79	004F
Harmonic I3 row 9	80	0050
Harmonic IN row 9	81	0051
Harmonic I1 row 11	82	0052
Harmonic I2 row 11	83	0053
Harmonic I3 row 11	84	0054
Harmonic IN row 11	85	0055
Harmonic I1 row 13	86	0056
Harmonic I2 row 13	87	0057
Harmonic I3 row 13	88	0058
Harmonic IN row 13	89	0059
Harmonic I1 row 15	90	005A
Harmonic I2 row 15	91	005B
Harmonic I3 row 15	92	005C
Harmonic IN row 15	93	005D
Thd U12	94	005E
Thd U23	95	005F
Thd U31	96	0060
Harmonic U12 row 3	97	0061
Harmonic U23 row 3	98	0062
Harmonic U31 row 3	99	0063
Harmonic U12 row 5	100	0064
Harmonic U23 row 5	101	0065

MODULE 9: SPECIAL FRAME

List of values

Name	Decimal address	Hexa. address
Harmonic U31 row 5	102	0066
Harmonic U12 row 7	103	0067
Harmonic U23 row 7	104	0068
Harmonic U31 row 7	105	0069
Harmonic U12 row 9	106	006A
Harmonic U23 row 9	107	006B
Harmonic U31 row 9	108	006C
Harmonic U12 row 11	109	006D
Harmonic U23 row 11	110	006E
Harmonic U31 row 11	111	006F
Harmonic U12 row 13	112	0070
Harmonic U23 row 13	113	0071
Harmonic U31 row 13	114	0072
Harmonic U12 row 15	115	0073
Harmonic U23 row 15	116	0074
Harmonic U31 row 15	117	0075
Thd V1	118	0076
Thd V2	119	0077
Thd V3	120	0078
Harmonic V1 row 3	121	0079
Harmonic V2 row 3	122	007A
Harmonic V3 row 3	123	007B
Harmonic V1 row 5	124	007C
Harmonic V2 row 5	125	007D
Harmonic V3 row 5	126	007E
Harmonic V1 row 7	127	007F
Harmonic V2 row 7	128	0080
Harmonic V3 row 7	129	0081
Harmonic V1 row 9	130	0082
Harmonic V2 row 9	131	0083
Harmonic V3 row 9	132	0084
Harmonic V1 row 11	133	0085
Harmonic V2 row 11	134	0086
Harmonic V3 row 11	135	0087
Harmonic V1 row 13	136	0088
Harmonic V2 row 13	137	0089
Harmonic V3 row 13	138	008A
Harmonic V1 row 15	139	008B
Harmonic V2 row 15	140	008C
Harmonic V3 row 15	141	008D
I System	142	008E
U System	143	008F
V System	144	0090
Hour meter < 10000	145	0091
Hour meter > 10000	146	0092

USE OF THE PROFIBUS®-DP MODULES

MODULE 9: SPECIAL FRAME

Name	Decimal address	Hexa. address
Last voltage dips		
Residual phase to phase involved: 0: none, 5: U12 6: U23 7: U31	4096	1000
Msb value (V/100)	4097	1001
Isb value (V/100)	4098	1002
Residual phase to neutral involved 0: none 22 : V1 23: V2 24: V3	4099	1003
Msb value (V/100)	4100	1004
Isb value (V/100)	4101	1005
Msb length (ms)	4102	1006
Isb length (ms)	4103	1007
Day	4104	1008
Month	4105	1009
Year	4106	100A
Hour	4107	100B
Minute	4108	100C
Second	4109	100D
Last power interruption		
Day	4110	100E
Month	4111	100F
Year	4112	1010
Hour	4113	1011
Minute	4114	1012
Second	4115	1013
Last average power		
Last P+ value (W)	4116	1014
Last P- value (W)	4117	1015
Last Q+ value (var)	4118	1016
Last Q- value (var)	4119	1017
Average frequency		
Last frequency value (Hz/100)	4120	1018
Last swell		
Maximum phase to phase involved 0: none 5: U12 6: U23 7: U31	4121	1019
Isb value (V/100)	4122	101A
Msb value (V/100)	4123	101B
Maximum phase to neutral involved 0: none 22 : V1 23: V2 24: V3	4124	101C

MODULE 9: SPECIAL FRAME

Name	Decimal address	Hexa. address
Isb value (V/100)	4125	101D
Msb value (V/100)	4126	101E
Msb length (ms)	4127	101F
Isb length (ms)	4128	1020
Month	4129	1021
Day	4130	1022
Year	4131	1023
Hour	4132	1024
Minute	4133	1025
Second	4134	1026
Average voltage		
Last value U12 (V/10)	4135	1027
Last value U23 (V/10)	4136	1028
Last value U31 (V/10)	4137	1029
Last value U1 (V/10)	4138	102A
Last value U2 (V/10)	4139	102B
Last value U3 (V/10)	4140	102C
New values available		
Average In (mA)	4141	102D
Average maximum In (mA)	4142	102E

Note:

msb: most significant byte.

Isb: least significant byte.

Input frame

Name	Size (bytes)
Frame number	1
Value 1	2
Value 2	2
Value 3	2
Value 4	2
Value 5	2
Value 6	2
Value 7	2
Value 8	2
Value 9	2
Value 10	2
Value 11	2
Value 12	2
Value 13	2
Value 14	2
Value 15	2
Value 16	2

Length: 33 bytes

USE OF THE PROFIBUS®-DP MODULES

MODULE 10 : RESERVED FOR MANUFACTURER

MODULE 11 : SIZE LIMITED SPECIAL FRAME

This module allows the creation of a personalised module of 4 values.

Output frame

Name	Size (bytes)
Frame number	1
Address of value 1	2
Address of value 2	2
Address of value 3	2
Address of value 4	2

Length: 9 bytes

NB:

The frame number is an identification number. It is used to check if the answer coming from the slave device corresponds to the PLC's request.

The list of values is available p. 31 to 35 (module 9).


Input frame

Name	Size (bytes)
Frame number	1
Value 1	2
Value 2	2
Value 3	2
Value 4	2

Length: 9 bytes

DIAGNOSTICS

These contain an indication of the presence of **DIRIS A-30/A-41** option modules, the serial number, the **DIRIS A-30/A-41** product code and the presence of an alarm or an excess.



Name	Size (bytes)
Option present on slot 1 0: RS485 1: Metering 3: Harmonics F0: In 20: 2 In / 2 out 30: 2 0 / 4 - 20 mA 50: PROFIBUS®-DP	1
Option present on slot 2 0: RS485 1: Metering 3: Harmonics F0: In 20: 2 In / 2 out 30: 2 0 / 4 - 20 mA 50: PROFIBUS®-DP	1
Option present on slot 3 0: RS485 1: Metering 3: Harmonics F0: In 20: 2 In / 2 out 30: 2 0 / 4 - 20 mA 50: PROFIBUS®-DP	1
Option present on slot 4 0: RS485 1: Metering 3: Harmonics F0: In 20: 2 In / 2 out 30: 2 0 / 4 - 20 mA 50: PROFIBUS®-DP	1

DIAGNOSTICS

Name	Size (bytes)
Serial number	4
Product code	1
Alarms bit 0: Alarm I bit 1: Alarm In bit 2: Alarm U bit 3: Alarm V bit 4: Alarm P+ bit 5: Alarm Q+ bit 6: Alarm S bit 7: Alarm F bit 8: Alarm PFL bit 9: Alarm Time bit 10: Alarm Thd I bit 11: Alarm Thd In bit 12: Alarm Thd U bit 13: Alarm Thd V bit 14: Alarm P- bit 15: Alarm Q- bit 16: Alarm PFC bit 17-31: not used	4
Excesses bit 0: Excess I bit 1: Excess In bit 2: Excess U bit 3: Excess V bit 4: Excess P+ bit 5: Excess Q+ bit 6: Excess S bit 7: Excess F bit 8: Excess PFL bit 9: Excess Time bit 10: Excess Thd I bit 11: Excess Thd In bit 12: Excess Thd U bit 13: Excess Thd V bit 14: Excess P- bit 15: Excess Q- bit 16: Excess PFC bit 17-31: not used	4

Length: 17 bytes

TECHNICAL CHARACTERISTICS

COMMUNICATION

RS485	2 or 3 wires half duplex
Protocol	PROFIBUS®-DP
Speed	9.6 to 1500 kbauds
Galvanic insulation	4 kV
UL-CSA Approval	
Standard	UL 61010-1 CSA-C22.2 No. 61010-1
Certificate	UL file No: E257746

GLOSSARY OF ABBREVIATIONS

COM	Communication
ADR	Slave address
DIAG	Diagnostic function activated or not
PARA	Remote parametering activated or not



536182C

HEAD OFFICE

SOCOMEK GROUP

SAS SOCOMEK capital 10 633 100 €
R.C.S. Strasbourg B 548 500 149
B.P. 60010 - 1, rue de Westhouse
F-67235 Benfeld Cedex
Tel. +33 3 88 57 41 41 - Fax +33 3 88 57 78 78
info.scp.isd@socomec.com

www.socomec.com



YOUR DISTRIBUTOR / PARTNER
