



Ref. Certif. No.

CN55379

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

SWITCH DISCONNECTOR

Name and address of the applicant

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

SOCIETE TIMELEC SARL
ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA
NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS,
Tunisia

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

 Additional information on page 2

See the Appendix

Trademark / Brand (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SIRCO 315A, SIRCO 400A, SIRCO 500A, SIRCO 630A, SIRCO CD
800A

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2020 in conjunction with IEC 60947-1:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-099884

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRESection 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Dec.21,2021

Signature:

Xie ZhaoXu

CB 0066105

SIRCO 315A, SIRCO 400A, SIRCO 500A, SIRCO 630A, SIRCO CD 800A

Uimp: 12kV;

Ui: 1000V;

Ith: 315A(SIRCO 315A), 400A(SIRCO 400A), 500A(SIRCO 500A),
630A(SIRCO 630A), 800A(SIRCO CD 800A);

Ue: AC415V;

Ie: 315A(SIRCO 315A), 400A(SIRCO 400A), 500A(SIRCO 500A),
630A(SIRCO 630A), 800A(SIRCO CD 800A);

Icw:13kA/1s(SIRCO 315A, SIRCO 400A, SIRCO 500A, SIRCO 630A),16kA/1s(SIRCO CD
800A);

Icm(Peak):26kA(SIRCO 315A, SIRCO 400A, SIRCO 500A, SIRCO 630A),32kA(SIRCO CD
800A);

Iq: 100kA(SIRCO 315A, SIRCO 400A, SIRCO 500A), 70kA(SIRCO 630A);

Utilization category: AC-22A(SIRCO 630A), AC-22B(SIRCO CD 800A),AC-23A(SIRCO 315A,
SIRCO 400A, SIRCO 500A);

Number of poles:3P,4P;

Rated frequency :50/60Hz

Page 1 of 1

Additional information (if necessary)

Date: Dec.21,2021

Signature:

谢肇旭

Xie ZhaoXu

IEC**IECEE**

®

™

Ref. Certif. No.

CN55379

| Name of the factory | Address of the factory |
|---------------------|--|
| 1.SOCOMECS.A.S | 1, Rue De Westhouse 67230 Benfeld Cedex France |

Additional information (if necessary)

Date: Dec.21,2021

Signature:

Xie ZhaoXu