



Certificate of Compliance

Certificate: 2316514

Master Contract: 189705 (112964)

Project: 70217714

Date Issued: 2019-03-21

Issued to: Socomec S.A.
rue de Westhouse 1
BP 10
Benfeld Cedex, Bas-Rhin 67235
FRANCE

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Patrick Quinty*
Patrick Quinty

PRODUCTS

CLASS - C465102 - SWITCHES-Dead-front (Open Type)

Part A

Open Type Switches, Manual, Cat. No. 22013003 – 22013006 – 22003010 and 22BU3010 can be added with a fourth pole 22011003 for the 30A rating, or with a fourth pole 60A cat no. 22011006 or for the fourth pole 100A cat no. 22001010.

Rating:

Cat no.22013003 or 22011003: 25HP max at 600Vac, 3 ph; 10HP max at 480Vac, 1ph; 5HP max at 250Vdc; 10 AWG to 2/0 AWG; wires; General use 30A at 600Vac, 30A at 250Vdc. Short-circuit rating: 100kA at 600Vac.

Cat no.22013006 or 22011006: 50HP max at 600Vac, 3 ph; 25HP max at 480Vac, 1ph; 10HP max at 250Vdc; 6 AWG to 2/0 AWG; wires; General use 60A at 600Vac, 60A at 250Vdc. Short-circuit rating: 100kA at 600Vac.

Cat no.22003010 or 22001010: 50HP max at 600Vac, 3 ph; 25HP max at 480Vac, 1ph; 15HP max at 250Vdc; 3 AWG to 2/0 AWG; wires; General use 100A at 600Vac, 100A at 250Vdc. Short-circuit rating: 100kA at 480Vac, 25kA at 600Vac.

Solid Neutral pole with Cat Nos 22005011 and Solid earthing pole with Cat Nos 22009011.



Certificate: 2316514
Project: 70217714

Master Contract: 189705
Date Issued: 2019-03-21

Note: Cat. No. 22BU3010 is Cat. No. 22003010 with the handle Cat. No. 22995032 already mounted on the switch.

Part B

Terminal shroud Cat. Nos. 22943016, 22941011, 2B943016.

Part C

Component handle Cat. Nos. 22995032.

Note:

- 1) These devices are manual open type switches intended for general use and having ampere ratings with horsepower ratings.
- 2) For use in enclosures minimum size 12 by 8 by 6 in for catalogue number 22013003, 22011003, 22013006, 22011006 and enclosure minimum size 14 by 8 by 6 for catalogue number 22003010, 22001010.
- 3) The terminal shroud Cat. Nos. 22943016 and 2B943016 are for use with 3 pole switches, Cat. Nos. 22013003, 22013006, 22003010.
- 4) The terminal shroud Cat Nos 22941011 is for use with the four pole switches Cat. Nos. 22011003, 22011006, 22001010.
- 5) The handle is for use with 3 pole switches, Cat. Nos. 22013003, 22013006, 22003010 or equipped with a four pole switches Cat. Nos. 22011003, 22011006, 22001010.
- 6) These devices are certified as components for use in equipment where the suitability of the combination is determined by CSA International.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 4-16 - Enclosed Switches



Supplement to Certificate of Compliance

Certificate: 2316514

Master Contract: 189705 (112964)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70217714	2019-03-21	Addition of model 22BU3010 and 2B943016.
70107196	2017-11-13	Update report as per Notice 17 and 21 (CSA C22.2 No.4-16).
70084314	2016-07-29	Modification of wire gauge and torque.
2316514	2010-09-14	New certification: Open type switches, manual, Sirco M3. Catalogue number 3 poles: 22013006, 22003010; 4 poles: 22011003, 22011006, 22001010. As per CSA C22.2 No.4-04.