

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2018010302085604

Valid from: Apr.21,2020

Valid until: Jul.20,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT	SOCOMECA S.A 1, Rue De Westhouse 67230 Benfeld Cedex France
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	SOCOMECA S.A 1, Rue De Westhouse 67230 Benfeld Cedex France
NAME AND LOCATION OF THE FACTORY	SOCOMECA INDIA PRIVATE LIMITED 756,Pace City-II,Sector 37,Gurgaon-122001,Haryana,India
PRODUCT NAME, MODEL AND SPECIFICATION	Switch disconnecter SIDER 125A inside, SIDER 200A inside : Ui : 800V; Uimp:8kV; Ue: AC415V; Ith: 125A, 200A; Ie: AC-22A:125A, 200A, AC-23A: 100A, 200A; Icw: 7kA/1s, 9kA/1s; Icm(Peak): 12kA, 17kA; Utilization Category: AC-22A,AC-23A; Poles: 3P;IP55
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T14048.3-2017
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

陆楠



CHINA QUALITY CERTIFICATION CENTRE