

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2017010302996157

Valid from: Jul.29,2020

Valid until: Jul.20,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT	SOCOMECHINA Co.,Ltd. Unit k, 6/F, No.258 , Fute North Road, Pilot Free Trade Zone Shanghai, P.R.China
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	SOCOMECH S.A 1, Rue De Westhouse 67230 Benfeld Cedex France
NAME AND LOCATION OF THE FACTORY	SOCOMECH S.A 1 , Rue de Westhouse 67230 BENFELD CEDEX FRANCE
PRODUCT NAME, MODEL AND SPECIFICATION	Load Break Isolator SIDERMAT 63A,SIDERMAT 100A,SIDERMAT 160A,SIDERMAT 250A,SIDERMAT 400A,SIDERMAT 630A; Uimp:12kV; Ui: 1000V; Ith: 63A,100A,160A,250A, 400A, 630A; Ue: AC415V; Ie: 63A,100A,160A,250A,400A,630A; Icw:9kA/1s(63A,100A,160A,250A), 14kA/1s (400A), 25kA/1s (630A); Icm(Peak Value): 19kA(63A,100A,160A,250A),28kA(400A),35kA(630A); Utilization Category : AC-22B; Poles : 3P,4P;
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.3-2017
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Apr.10,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

陆楠



CHINA QUALITY CERTIFICATION CENTRE