

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2019010302223828

Valid from: Jul.19,2021

Valid until: Jul.19,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT
SOCOMEC S.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER
SOCOMEC S.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

NAME AND LOCATION OF THE FACTORY
SOCOMEC INDIA PRIVATE LIMITED
756,Pace City-II,Sector 37,Gurgaon-122001,Haryana,India

PRODUCT NAME, MODEL AND SPECIFICATION
Switch-disconnector
SIRCO PV 160A,SIRCO PV 250A,SIRCO PV 315A,SIRCO PV 400A ; See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS
GB/T 14048.3-2017

TYPE OF CERTIFICATION SCHEMES
Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Apr.21,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

谢肇煦

CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

Tel: +86 10 83886666

C(2) 0083322

产品认证证书

II型自愿认证

证书编号: CQC2019010302223828

第 1 页 共 2 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 83322

SIRCO PV 160A, SIRCO PV 250A, SIRCO PV 315A, SIRCO PV 400A;

Ue: DC1500V;

Ui: 1500V; Uimp: 12kV;

Ie: 160A、250A、315A、400A;

Ith: 160A、250A、315A、400A;

Icm(峰值): 10kA;

使用类别: DC-PV1;

接线方式: 3P 外形; 直流接线图见附页;



中国质量认证中心



产品认证证书

II型自愿认证


证书编号: CQC2019010302223828

第 2 页 共 2 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 83322

直流接线图



中国质量认证中心

