



Ref. Certif. No.

US-42815-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Energy measuring and monitoring device

Name and address of the applicant

SOCOMECSAS
1 Rue de Westhouse B.P. 60010
67235 Benfeld Cedex FRANCE

Name and address of the manufacturer

SOCOMECSAS
1 Rue de Westhouse B.P. 60010
67235 Benfeld Cedex FRANCE

Name and address of the factory

CONTINENTAL CONTROL SYSTEMS L L C
2150 Miller Dr, Suite A Longmont, CO 80501
United States

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

DIRIS A-100:
SUPPLY
115-600V~ L/L L/N (5VA)
☒ Additional Information on page 2

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

DIRIS A-100, DIRIS A-200

Additional information (if necessary may also be reported on page 2)

Additionally evaluated to: EN 61010-1:2010, EN 61010-1:2010/A1:2019,
EN IEC 61010-2-030:2021
National Differences: EU Group Differences, CA, US
☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61010-1:2010, IEC 61010-1:2010/AMD1:2016, IEC 61010-2-030:2017

As shown in the Test Report Ref. No. which forms part of this Certificate

E257746-D1016-1/A0/C0-ULCB issued on 2023-08-31

This CB Test Certificate is issued by the National Certification Body



- ☒ UL Solutions (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- ☐ UL Solutions (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- ☐ UL Solutions (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- ☐ UL Solutions (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2023-10-09

Signature:

Jolanta M. Wroblewska



Ref. Certif. No.

US-42815-UL

Additional Ratings:

50-60Hz
VOLTAGE
50-600V~ L/N CAT III
90-690V~ L/L CAT III

DIRIS A-200:
SUPPLY 115-600V~ L/L L/N (7VA)
50-60Hz
VOLTAGE
50-600V~ L/N CAT III
90-690V~ L/L CAT III

Additional information (if necessary)



- ☒ UL Solutions (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- ☐ UL Solutions (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- ☐ UL Solutions (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- ☐ UL Solutions (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2023-10-09

Signature:

Jolanta M. Wroblewska