



Certificate of Compliance

Certificate: 2235013 **Master Contract:** 189705
Project: 80177504 **Date Issued:** 12/05/2023
Issued to: Socomec S.A.
rue de Westhouse 1
BP 10
Benfeld Cedex, Bas-Rhin 67235
France
Attention: Cyril Hassenfratz

The products listed below are eligible to bear the CSA Mark shown



Issued by: Steven Montminy
Steven Montminy

PRODUCTS

C465102 SWITCHES - Dead-front (Open Type)

Part A: Open Type Switches, Manual

Fuserbloc J30

Models	Current (A)	Voltage (V max)	Max. Power (HP)	Short Circuit Rating (kA)	Number of Contacts	Pole(s)	Wire Range (AWG)
38512004, 38513004, 38516004, 38612004, 38613004, 38616004, 37172004, 37173004, 37176004	General Use: 30A	600Vac	25 HP	200kA	Single	2 to 4 poles	10AWG stranded or solid copper wire
	General Use: 30A	250Vdc	5HP	100kA	Single	2 to 4 poles	10AWG stranded or solid copper wire

Fuserbloc J60



Certificate: 2235013

Master Contract: 189705

Project: 80177504

Date Issued: 12/05/2023

Models	Current (A)	Voltage (V max)	Max. Power (HP)	Short Circuit Rating (kA)	Number of Contacts	Pole(s)	Wire Range (AWG)
38512005, 38513005, 38516005, 38612005, 38613005, 38616005, 37172005, 37173005, 37176005	General Use: 60A	600Vac	50 HP	100kA	Single	2 to 4 poles	6AWG stranded copper wire
	General Use: 60A	250Vdc	10 HP	100kA	Single	2 to 4 poles	6AWG stranded copper wire

Part B: Open Type Switches, Manual

Fuserbloc J60

Models	Current (A)	Voltage (V max)	Max. Power (HP)	Short Circuit Rating (kA)	Number of Contacts	Pole(s)	Wire Range (AWG)
38512006, 38513006, 38516006, 38612006, 38613006, 38616006, 37172006, 37173006, 37176006	General Use: 60A	600Vac	50 HP	200kA	Double	2 to 4 poles	10AWG to 8AWG Solid copper wire / 10AWG to 2/0 AWG Compact-stranded copper wire
	General Use: 60A	250Vdc	10 HP	100kA	Double	2 to 4 poles	10AWG to 8AWG Solid copper wire / 10AWG to 2/0 AWG Compact-stranded copper wire

Fuserbloc J100

Models	Current (A)	Voltage (V max)	Max. Power (HP)	Short Circuit Rating (kA)	Number of Contacts	Pole(s)	Wire Range (AWG)
38512010, 38513010, 38516010, 38612010, 38613010, 38616010, 37172010, 37173010, 37176010	General Use: 100A	600Vac	75 HP	200kA	Double	2 to 4 poles	10AWG to 8AWG Solid copper wire / 10AWG to 2/0 AWG Compact-stranded copper wire
	General Use: 100A	250Vdc	20 HP	100kA	Double	2 to 4 poles	10AWG to 8AWG Solid copper wire / 10AWG to 2/0 AWG Compact-stranded copper wire



Certificate: 2235013

Master Contract: 189705

Project: 80177504

Date Issued: 12/05/2023

Part C: Adaptation kits for flange handle

Models
39299992, 39299993, 39299994

39299992, 39299993, 39299994, to be used with Rockwell handles Cat. No. 1494F-P1, 1494F-M1 and 1494F-S1 or fused switches series Fuserbloc J100, cat. No. 38613010.



Certificate: 2235013

Project: 80177504

Master Contract: 189705

Date Issued: 12/05/2023

APPLICABLE REQUIREMENTS

CSA C22.2 No. 4-16 +Upd.1 (Eighth Edition) (R2020) - Enclosed and dead-front switches



Certificate: 2235013


Project: 80177504

Master Contract: 189705

Date Issued: 12/05/2023

Notes:

Products certified under Class C465102 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 2235013

Master Contract: 189705

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80177504	December 05, 2023	Update of report 189705-2235013 to change of the terminal clamp's manufacturer and cable section of 60A switch and update of manufacturer name of plastic material base on acceptance of test data.
80073256	March 11, 2021	Updates of report 189705-2235013 to cover addition of alternate plastic material manufactured by Domo Polytechnyl Sas to the component "cam" (item 8) of switching module (part A and B), in accordance with the standard CSA C22.2 No.4-16 with update 1 as per certification notice no. 24.
000070107193	September 12, 2017	Update report as per Notice 21 (CSA C22.2 No.4-16).
000070089914	August 18, 2016	Modification of wire gauge and torque.
000070050804	November 19, 2015	Modification of the plastic manufacturer.
0002753089	August 19, 2014	Addition of Adaptation kit for flange handle, Cat. No. 39299992, 39299993 & 39299994.
0002676045	January 13, 2014	Modification of short-circuit rating of 250Vdc at 100kA.
0002529482	July 12, 2012	Addition of optional auxiliary holder, operating peg, handle cat no. 194R- HM4—N2-L and auxiliary contact cat nos 800x10, 800x01 by Rockwell into cat no. Fuserbloc J100.
0002478890	December 07, 2011	Clarification of terminal clamp description
0002235013	November 27, 2009	New certification of Fuse switch model FUSERBLOC J30, J60 and J100